



- NOTES**
- 1.0 ALL FANS SHALL BE LOW NOISE AND BE COMPLETE WITH TAMPERPROOF FITTINGS.
  - 2.0 DUCTWORK SHALL BE INSTALLED IN ACCORDANCE WITH LOCAL SPECIFICATION AND SHALL BE IDENTIFIED BY MEANS OF DUCTWORK IDENTIFICATION FOR STEEL IDENTIFICATION.
  - 3.0 INTERNAL GRILLS AND DIFFUSERS SHALL BE TAMPERPROOF. ALL GRILLS SHALL HAVE A POWERS COATED FINISH TO A COLOUR TO BE AGREED WITH THE ARCHITECT.
  - 4.0 FIRE DAMPERS SHALL BE PROVIDED WHERE NECESSARY TO MAINTAIN THE INTEGRITY OF THE DUCTWORK THROUGH FIRE RATED CONSTRUCTION.
  - 5.0 ALL VENTILATION SYSTEMS SHALL BE TESTED IN ACCORDANCE WITH DSEB COMMISSIONING CODE A.

- LEGEND**
- ☐ SQUARE CEILING SUPPLY AIR DIFFUSER
  - ☐ SQUARE CEILING EXTRACT AIR DIFFUSER
  - ∞ AXIAL/ANGLED FLOW FAN
  - ⊙ WALL FAN
  - ⊙ HEATING COIL
  - ⊙ PANEL FILTER
  - ⊙ PAD FILTER
  - ⊙ ATTENUATOR
  - ⊙ FIRE DAMPER
  - ⊙ VOLUME CONTROL DAMPER
  - ⊙ FLEXIBLE DUCTWORK CONNECTION
  - ⊙ AIR TRANSFER GRILLE
  - ⊙ AIR TRANSFER SQUARE BEAND
  - ⊙ DUCTWORK ACCESS DOOR